



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

04/13/16

Gary Sisk
Ashland School District #5/Maintenance Dept.
885 Siskiyou Blvd.
Ashland, OR 97520

TEL: (541) 601-6680

FAX: (541) 488-6102

RE: Brisco Elementary

Order No.: 1604284

Dear Gary Sisk:

Neilson Research Corporation received 2 sample(s) on 04/07/16 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Ashland School District #5/Maintenance De
Project: Brisco Elementary
Lab Order: 1604284

Date: 13-Apr-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Ashland School District #5/Maintenance
885 Siskiyou Blvd.
Ashland, OR 97520

Lab Order: **1604284**
NRC Sample ID: **1604284-01A**
Collection Date: **04/07/16 5:50:00 AM**
Received Date: **04/07/16 10:20:00 AM**
Reported Date: **04/13/16 4:44:40 PM**

Brisco Elementary

PWS ID#:
Source ID:
Sample Comp:

Client Sample ID: Kitchen Sink
Sample Location:
Collectors Name: Dave Sommer

ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.00199		0.0001	mg/L	0.015 A	04/12/16	BAR

Notes: ND - Not Detected at the MRL
MDL = Method Detection Limit

N.L. = No Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Ashland School District #5/Maintenance
885 Siskiyou Blvd.
Ashland, OR 97520

Lab Order: **1604284**
NRC Sample ID: **1604284-02A**
Collection Date: **04/07/16 5:55:00 AM**
Received Date: **04/07/16 10:20:00 AM**
Reported Date: **04/13/16 4:44:40 PM**

Brisco Elementary

PWS ID#:
Source ID:
Sample Comp:

Client Sample ID: Break Room Sink
Sample Location:
Collectors Name: Dave Sommer

ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.00669		0.0001	mg/L	0.015 A	04/12/16	BAR

Notes: ND - Not Detected at the MRL
MDL = Method Detection Limit

N.L. = No Limit

CLIENT: Ashland School District #5/Maintenance De
 Work Order: 1604284
 Project: Brisco Elementary

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_DW

Sample ID: MB-34933	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288484						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000100

Sample ID: LCS-34933	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288485						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09809 0.000100 0.1 0 98.1 85 115

Sample ID: 1604361-01AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288505						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09704 0.000100 0.1 0.0004207 96.6 70 130

Sample ID: 1604361-01AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288506						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09710 0.000100 0.1 0.0004207 96.7 70 130 0.09704 0.0618 20

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

