



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

04/13/16

Gary Sisk
Ashland School District #5/Maintenance Dept.
885 Siskiyou Blvd.
Ashland, OR 97520

TEL: (541) 601-6680

FAX: (541) 488-6102

RE: Bellview Elementary

Order No.: 1604285

Dear Gary Sisk:

Neilson Research Corporation received 2 sample(s) on 04/07/16 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Ashland School District #5/Maintenance De
Project: Bellview Elementary
Lab Order: 1604285

Date: 13-Apr-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Ashland School District #5/Maintenance
885 Siskiyou Blvd.
Ashland, OR 97520

Lab Order: **1604285**
NRC Sample ID: **1604285-01A**
Collection Date: **04/07/16 5:00:00 AM**
Received Date: **04/07/16 10:20:00 AM**
Reported Date: **04/13/16 4:46:02 PM**

Bellview Elementary

PWS ID#:
Source ID:
Sample Comp:

Client Sample ID: Teacher Break Room
Sample Location:
Collectors Name: Connie Rainwater

ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.00117		0.0001	mg/L	0.015 A	04/12/16	BAR

Notes: ND - Not Detected at the MRL
MDL = Method Detection Limit

N.L. = No Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Ashland School District #5/Maintenance
885 Siskiyou Blvd.
Ashland, OR 97520

Lab Order: **1604285**
NRC Sample ID: **1604285-02A**
Collection Date: **04/07/16 5:00:00 AM**
Received Date: **04/07/16 10:20:00 AM**
Reported Date: **04/13/16 4:46:02 PM**

Bellview Elementary

PWS ID#:
Source ID:
Sample Comp:

Client Sample ID: Drinking Fountain Lions Den
Sample Location:
Collectors Name: Connie Rainwater

ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.00138		0.0001	mg/L	0.015 A	04/12/16	BAR

Notes: ND - Not Detected at the MRL
MDL = Method Detection Limit

N.L. = No Limit

CLIENT: Ashland School District #5/Maintenance De
 Work Order: 1604285
 Project: Bellview Elementary

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_DW

Sample ID: MB-34933	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288484						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.000100									
------	----	----------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-34933	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288485						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.09809	0.000100	0.1	0	98.1	85	115				
------	---------	----------	-----	---	------	----	-----	--	--	--	--

Sample ID: 1604361-01AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288505						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.09704	0.000100	0.1	0.0004207	96.6	70	130				
------	---------	----------	-----	-----------	------	----	-----	--	--	--	--

Sample ID: 1604361-01AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288506						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.09710	0.000100	0.1	0.0004207	96.7	70	130	0.09704	0.0618	20	
------	---------	----------	-----	-----------	------	----	-----	---------	--------	----	--

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits



NEILSON RESEARCH CORPORATION
 Environmental Testing Laboratory
 245 South Grape Street * Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
Required Client Information

Company: Bellview School Dist
 Address: 885 Siskiyaw Blvd
 Bellview, Oregon
 Email: gary.sisk@bellview.k12.or.us
 Phone: 541-767-1430 Fax:
 Collected By (Print): Connie Rainwater
 Collected By (Sign): Connie Rainwater
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B
Required Project Information

Project Name: Bellview School
 Project Number: 88
 Report To: Gary Sisk
 Copy To: Gary Sisk
 P.O. #: 164403

Section C
Invoice Information

Attention: Gary Sisk
 Company Name: Bellview School
 Address: 885 Siskiyaw Blvd

Section D
Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested
<u>Teachers Break Rm.</u>		<u>DW</u>	<u>4-7-16</u>	<u>5:00am</u>	<u>1</u>	<u>Lead</u>
<u>Drinking Water Lions Bldg</u>		<u>DW</u>	<u>4-7-16</u>	<u>5:00am</u>	<u>1</u>	<u>OT</u>

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive Sign

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>Semmy Bachucha</u>	<u>[Signature]</u>	<u>CONNIE RAINWATER</u>	<u>4-7-16</u>	<u>8:15am</u>
Received By: <u>Gary Sisk</u>	<u>[Signature]</u>	<u>GARY SISK</u>	<u>4-7-16</u>	<u>8:20am</u>
Relinquished By: <u>Gary Sisk</u>	<u>[Signature]</u>	<u>GARY SISK</u>	<u>4-7-16</u>	<u>8:24am</u>
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By Laboratory:		<u>Cynthia Lewis</u>	<u>4-7-16</u>	<u>10:30</u>

Section G
Lab Use Only

NRC Workorder # 1604285
 (Lab Use Only)
 Remarks/Field Data
 NRC Sample # OT
 (Lab Use Only)
 Temp: _____
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: _____
 pH Checked: _____
 COC Seals Intact: Yes No
 Field Blank Included: Yes No

Received Via UPS FedEx Other _____ Hand _____
 Payment: Invoice Cash VISA, M/C Check # _____ Amount _____

Bellview School
1677 Tolman Brook Rd.